



ORANGE COVE FIRE PROTECTION DISTRICT

550 Center Street • Orange Cove, CA 93646

Office (559) 626-7758 • Fax (559) 626-3909

On the web visit: www.orangecovefire.com

FIREWORKS STAND INSPECTION

Each fireworks stand must have the following posted prior to the initial inspection:

- State Fire Marshal's license
- Temporary Seller's Permit from the State Board of Equalization
- Certificate of Insurance
- Name and contact information of two people responsible for the operation of the fireworks stand

The fireworks stand must be at least 10 feet from the following:

- Parking- Block off parking prior to initial inspection
- Public sidewalk or roadway

The fireworks stand must be at least 25 feet from the following:

- Any adjacent buildings
- Property line or burnable materials, including dry vegetation
- Fireworks storage container
- Generators or associated fuel supplies

The fireworks stand must be at least 100 feet from the following:

- Any pump, dispensing device, or fill location for flammable and/or combustible liquids and/or gases

Other fireworks stand requirements:

- Each stand will have a minimum of two exits on opposite sides, each with a minimum 32" wide clear width
- Only electric lights may be used, and the wiring shall meet the minimum requirements of the California Electrical Code. **All exposed bulbs must be covered**
- Red lettered "NO SMOKING" signs shall be located on all sides of the stand. (In both English and Spanish)
- One approved 2A:10B: C portable fire extinguisher must be in the stand sale area and must be serviced within the last year
- Fireworks signs, sandwich boards, and advertisements shall be limited to the booth and no more than 30 feet surrounding the booth
- All persons within the fireworks stand or employed in the sales must be at least 18 years of age
- Stands may not obstruct any handicapped parking stall
- The legal age to buy fireworks is 16 years of age